

## Short Form Classification Report No. 17026G

### PRODUCT

DuPont Corian® (made in Turkey)

### SPONSOR

DuPont de Nemours (Belgium) BVBA

### PRODUCT DETAILS

#### Classification report No. 17026C

- Density: 1680 - 1750 kg/m<sup>3</sup>
- Thickness: (6 – 19) ± 0.6 mm (Glacier White)
- Thickness: (6 – 12) ± 0.6 mm (Bone, Vanilla, Glacier Ice, Bisque, Designer White, Cameo White and all colours with a calorific value lower than or equal to 9.9 MJ/kg)

#### Classification report No. 14825C

- Density: 1750 kg/m<sup>3</sup>
- Thickness: 12 mm
- Colour: Glacier White

### FIELD OF APPLICATION (SUMMARY)

#### Classification report No. 17026C

- Substrate: Euroclass D-s2,d0 or better
- Without an air gap
- Fixing: Glued onto the substrate using Fix all High tack glue (Soudal)

For a fully detailed field of application, see annex

#### Classification report No. 14825C

- Substrate: Euroclass A2-s1,d0 or better
- With air gap
- Fixing: Typical ventilated façade construction

For a fully detailed field of application, see annex

### CLASSIFICATION

**B-s1,d0**

### STANDARDS

Test standard: EN ISO 11925-2:2010/AC 2011 & EN 13823:2010

Classification standard: EN 13501-1:2007+A1:2009

SIGNED BY

APPROVED BY

*For and on behalf of WFRGENT nv*

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2010/AC:2011, EN 13823:2010 and EN 13501-1:2007+A1:2009, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification reports Nos **17026C** and **14825C** are available at **DuPont de Nemours (Belgium) BVBA**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.

Page 1 of 2

## Annex – Fully detailed field of application

### FIELD OF APPLICATION

#### Classification report No. 17026C

- Substrate: Euroclass D-s2,d0 or better with a nominal thickness of at least 10 mm and a nominal density of at least 510 kg/m<sup>3</sup>
- Without an air gap
- Fixing: Directly glued onto the substrate using Fix all high tack glue (Soudal) with a PCS value lower than or equal to 2.87 MJ/m<sup>2</sup>

#### Classification report No. 14825C

- Substrate: Euroclass A2-s1,d0 or better with a nominal thickness of at least 9 mm and a nominal density of at least 652.5 kg/m<sup>3</sup>
- With air gap
- Fixing: The fixing system is a typical ventilated façade construction consisting of horizontal and vertical profiles. The vertical profiles are attached to the substrate (the wall) with aluminium brackets. The Corian is hung on the horizontal rails with clasps.